



BALLISTIC PERFORMANCE

Windell Blast Ballistic Double Outward Opening 34mm BRG glazed doors has been tested to determine the ballistic resistance in accordance with the requirements and procedures set out within **BS EN 1522:1999** and **BS EN 1523:1999**

Classifications:

The Glazing system has successfully been tested with reference to possible armed attack to resist the following :

Test 1:	Universal Breech One @ Target Distance 10m with 7.62 x 39 121gn Steel Core Test ammunition	
	Sample: 1100mm x 2300mm	
	18 perpendicular and angle shots	Held @ av. 712m/s

Tested by: **DJ Goode and Associates**