



BALLISTIC PERFORMANCE

Windell Blast Ballistic Top Swing Window has been tested to determine the ballistic resistance in accordance with the requirements and procedures set out within **BS EN 1522:1999** and **BS EN 1523:1999**

Classifications:

The Glazing system has successfully been tested with reference to possible armed attack to resist the following :

Test 1:	Universal Breech One @ Target Distance 10m with 7.62 x 39 121gn Steel Core Test ammunition	
	Sample: 600mm x 600mm x 130mm	
	3 rounds fired at Glazing	Held

Test 2:	Universal Breech One @ Target Distance 10m with 7.62 x 39 121gn Steel Core Test ammunition	
	Sample: 600mm x 600mm x 130mm	
	10 rounds fired at Frame	Held

Tested by: **Wiltshire Ballistic Services**